

CERTIFICATE OF COMPLIANCE

Certificate Number 20150318-E247491
Report Reference E247491-20150227
Issue Date 2015-MARCH-18

Issued to: FANDIS SPA
VIA PER CASTELLETTO 69
28040 BORGIO TICINO NO ITALY

**This is to certify that
representative samples of**

COMPONENT - TEMPERATURE-INDICATING AND -
REGULATING EQUIPMENT

Operating humidity sensing control for HVAC application
Model: IGR35F may be followed by PAXx or PAXxx or Sxx
or Sxxx

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 60730-1 and CSA E60730-1:13 AUTOMATIC
ELECTRICAL CONTROLS FOR HOUSEHOLD AND
SIMILAR USE - PART 1: GENERAL REQUIREMENTS, UL
60730-2-13 AUTOMATIC ELECTRICAL CONTROLS FOR
HOUSEHOLD AND SIMILAR USE; PART 2: PARTICULAR
REQUIREMENTS FOR HUMIDITY SENSING CONTROLS


Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Recognized components are incomplete in certain constructional features or restricted in performance
capabilities and are intended for use as components of complete equipment submitted for investigation rather
than for direct separate installation in the field. The final acceptance of the component is dependent upon its
installation and use in complete equipment submitted to UL LLC.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

